



THE CORPORATION OF THE CITY OF BRAMPTON

BY-LAW

Number 177-82

To authorize a capital expenditure in the amount of \$3,162,000.00 for the undertaking by the Hydro-Electric Commission of the City of Brampton, of the Service Centre Expansion at Glidden Road and additions to the Distribution System

WHEREAS the Council of The Corporation of the City of Brampton desires to authorize the undertaking by the Hydro Electric Commission of the City of Brampton of the Service Centre Expansion at Glidden Road and additions to the Distribution System as set out in Schedule "A" hereto attached.

NOW THEREFORE the Council of The Corporation of the City of Brampton ENACTS as follows:

1. That the Hydro-Electric Commission of Corporation of the City of Brampton be authorized to undertake the Service Centre Expansion at Glidden Road and additions to the Distribution System, set out in Schedule "A" hereto attached at a total estimated cost of \$3,162,000.00.
2. That the Mayor and the Treasurer are hereby authorized in the name of and on behalf of the Corporation to borrow from time to time by way of promissory note from the Royal Bank of Canada, 1 Main Street North, Brampton, a sum or sums not exceeding in the aggregate \$3,162,000.00 for the aforementioned purpose and to give on behalf of the Corporation to the Royal Bank of Canada a promissory note or notes sealed with the Corporate Seal and signed by the Mayor and the Treasurer for the money so borrowed with interest which may be paid in advance or otherwise.

READ a FIRST, SECOND and THIRD TIME and PASSED in Open Council this 13th day of September 1982.


FRANK ANDREWS ACTING MAYOR


RALPH A. EVERETT CLERK

SCHEDULE "A"

Peel Village Recabling, Phase 6

27.6kV feeder, Steeles Avenue, 2nd - 3rd Line W.

Bramalea Industrial Park, south section

New 27.6kV, Goreway Drive, Estateview - Rosegarden

Feeder #4, Bramalea T.S. - Hwy. #10

Feeder #4, Bramalea T.S. - Underground egress

27.6kV feeder tie, Glidden Rd. - Heart Lake Rd.

Addition of 8400 sq. ft. of office space at Service Centre

Add motor operation and remote control to existing
airbreak switches (15)

27.6kV "F" type line switches, remote control