



REQUEST FOR FINAL INSPECTION

Public Work & Engineering – Street Lighting
1975 Williams Parkway
Brampton, ON L6S 6E5
311

Table with 2 columns: Label (Date, Electrical Contractor, Project Location) and empty input field.

The Contractor has performed its quality control by inspecting and confirming all of the following:

- Street Light Infrastructure installed as per design / As-Built drawings provided
Street Light poles, brackets and heads are straight and perpendicular to roadway
Street light system energized Date of energization (mm/dd/yyyy)
ESA Certificate of Inspection and ESA Approval to Connect documents provided to the City
Completed Appendix B Stringing Form provided to the City
Night Inspection has been carried out – All lights operating at full brilliance
Street Light handhole connections as per City Standard
Handhole covers properly secured with tamper proof screws
Street Light identification plates are installed and numbered as per design
Lamps have been date stamped with install date
Street Light lenses clean
Wattage stickers have been installed
Power supply and in-pole breaker nomenclature and Flower City labels installed (ie. SL####)
Power supply and in-pole breaker covers secured / locked
All temporary overhead wire removed
Boulevard restoration around street light plant is complete

I certify that the above street light works have all been inspected and completed in its entirety.

Name (Please Print) \_\_\_\_\_

Position \_\_\_\_\_

Signature \_\_\_\_\_

I would like to be present during the final inspection

FORWARD COMPLETED ORIGINAL FORM TO THE CITY REPRESENTATIVE
FOR INCOMPLETE ITEMS, ATTACH JUSTIFICATION ON SEPARATE SHEET