

NOTES:

- 1. PIPE TO BE 150mm dia C.S.P. 1.2mm THICK PERFORATED AS SHOWN, OR 100mm dia PVC WITH GEOTEXTILE FABRIC COMPLY TO 0PSS 1860.
- 2. FOR TREATMENT AT CB SEE O.P.S.D. # 216.021
- 3. FULL LENGTH UNDERDRAIN SHALL BE REQUIRED ON ALL STREETS AND IN ALL TYPES OF SUBBASE MATERIAL.



APPROVED: 2011/02/17

REV. 6

STANDARD SUBDRAINS

223

ORIGINAL: 1990/10/10

N.T.S